

# Kidde Fire Protection Inert Gas System (400 Series)



## Component Description:

### Slave Cylinder Gauge Assembly

Effective: August 2018  
KDS 38-400005-0XX Rev AA

#### FEATURES

- For Approvals, see the "COMPATIBILITY" table.
- REACH and RoHS compliant

#### DESCRIPTION

Slave Cylinder Gauge Assemblies provide a gauge option for all slave cylinders in a system. The Slave Cylinder Gauge Assemblies are connected to the valve's gauge port and can be normally open or normally closed (when under pressure). Slave Gauges must match the pressure in the cylinder. All cylinders in a system must be of equal size and pressure.

#### ORDERING INFORMATION

| Part Number   | Pressure Rating | Contact         |
|---------------|-----------------|-----------------|
| 38-400005-001 | 200 Bar         | Normally Open   |
| 38-400005-002 | 200 Bar         | Normally Closed |
| 38-400005-003 | 300 Bar         | Normally Open   |
| 38-400005-004 | 300 Bar         | Normally Closed |



#### COMPATIBILITY

| Series                                                   | DIOM P/N      | Approvals* |
|----------------------------------------------------------|---------------|------------|
| Kidde Fire Protection IGS                                | 06-237518-001 | LPCB       |
| * For additional listings, contact Kidde Fire Protection |               |            |

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. believes this data to be accurate, but it is published and presented without any guarantee or warranty whatsoever. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The fire suppression system design, installation, maintenance, service and troubleshooting must be performed by trained, authorized Kidde Fire Protection distributors for the product to work correctly. If you need more information on this product, or if you have a particular problem or question, contact Kidde Fire Protection, Buckinghamshire, HP14 3SX, United Kingdom. Telephone: +44 (0)1494 480410.

©2018 Kidde-Fenwal, Inc.

KP-38-2120

Kidde Fire Protection  
1st Floor, Stokenchurch House,  
Oxford Road, Stokenchurch,  
Buckinghamshire,  
HP14 3SX, United Kingdom  
Tel: +44 (0)1494 480410  
[www.kfp.co.uk](http://www.kfp.co.uk)